



# **Code for Facilities, Technology and Inspection for Governor Stations and Valve Stations of Gas Wholesale Business**

Deliberation/Resolution by Gas Technical Standards Committee : May 17, 2019

Approval by the Ministry of Trade, Industry & Energy : June 14, 2019



## Personnel

### Gas Technical Standards Committee

Chairman Kwang-Won Lee, Professor of Hoseo University

Vice-Chairman Seung-Hoon Nam, Principal Researcher of KRISS

Ex Officio Member Hui-Won Lee, Manager of Energy Safety Department, Ministry of Trade, Industry & Energy

Hae-Myeong Yang, Director of Technology and Safety, Korea Gas Safety Corporation

High-Pressure Gas Seung-Hoon Nam, Principal Researcher of KRISS

Beom-Seok Lee, Principal Professor of Kyung Hee University

Dong-Myeong Ha, Professor of Semyung University

Chang-Gi Kim, Principal Researcher of Korea Institute of Machinery and Materials

Hyuk-Myun Kwon, Director General of Occupational Safety & Health Research Institute

Su-Dong Byun, CEO of Q-Best

Liquefied Petroleum Gas Doo-Seon Park, Managing Director of Daesung Industrial Gas Co., Ltd

Hyeong-Hwan Ann, Professor of Korea National University of Transportation

Byeong-Hak Choei, Professor of Gangneung-Wonju National University

Seong-Min Lee, Director of KOGAS Research Institute

Yong-Gwon Lee, Vice-President of EG CNE Co.,Ltd

Gi-hyeon Jang, Director of Kiturmi

Jeong-Sik Chon, Direto of E1 CO., Ltd.



History of Establishment and Revision of KGS Code	
Code Number	KGS FS452 <sup>2019</sup>
Code Title	Code for Facilities, Technology and Inspection for Governor Stations and Valve Stations of Gas Wholesale Business

Date of Establishment/Revision	Description
December 30, 2008	Established (Notification of the Ministry of Knowledge Economy No. 2008-379)
September 25, 2009	Revised (Notification of the Ministry of Knowledge Economy No. 2009-357)
December 2, 2009	Revised (Notification of the Ministry of Knowledge Economy No. 2009-454)
January 3, 2011	Revised (Notification of the Ministry of Knowledge Economy No. 2010-489)
January 5, 2012	Revised (Notification of the Ministry of Knowledge Economy No. 2011-635)
July 26, 2013	Revised (Notification of the Ministry of Industry, Trade & Energy No. 2013-176)
October 14, 2013	Revised (Notification of the Ministry of Industry, Trade & Energy No. 2013-279)
November 17, 2014	Revised (Notification of the Ministry of Industry, Trade & Energy No. 2014-589)
January 7, 2015	Revised (Notification of the Ministry of Industry, Trade & Energy No. 2015-001)
April 14, 2015	Revised (Notification of the Ministry of Industry, Trade & Energy No. 2015-223)
July 3, 2015	Revised (Notification of the Ministry of Industry, Trade & Energy No. 2015-372)
August 7, 2015	Revised (Notification of the Ministry of Industry, Trade & Energy No. 2015-436)
November 4, 2015	Revised (Notification of the Ministry of Industry, Trade & Energy No. 2015-578)
January 8, 2016	Revised (Notification of the Ministry of Industry, Trade & Energy No. 2016-006)
June 16, 2016	Revised (Notification of the Ministry of Industry, Trade & Energy No. 2016-306)

[illegible]

## **Table of Contents**

1. General.....	1
1.1 Scope.....	1
1.2 Validity of Code .....	1
1.3 Definitions .....	1
1.4 Application of Other Codes (currently not used) .....	4
1.5 Interim Measures.....	4
1.5.1 Interim measure for vent stacks in governor stations and valve stations.....	4
1.5.2 Interim measure for facility standard and technical standard <Revised on July 26, 2013> .....	4
1.5.3 Interim measures for piping materials <Newly established on July 26, 2013> .....	5
1.5.4 Interim measures for overpressure safety devices <Newly established on July 26, 2013> .....	6
1.6 Restriction to Use of Appliances.....	6
2. Installation Standard.....	6
2.1 Layout Standard.....	6
2.2 Foundation Standard.....	7
2.3 Storage Facility Standard (not applicable).....	7
2.4. Governor Station (Valve Station) Standard<Newly established on July 26, 2013> .....	7
2.4.1 Materials of governor stations (valve stations).....	7
2.4.2 Construction of governor station (valve station) .....	7
2.4.3 Thickness and strength of governor station (valve station).....	8
2.4.4 Installation of governor (station) .....	8
2.5 Piping Facility Standard <Revised on July 26, 2013> .....	8
2.5.1 Preparation of piping drawings.....	8
2.5.2 Materials of piping facilities.....	9
2.5.3 Configuration of piping facilities .....	11
2.5.4 Thickness of piping facilities.....	11
2.5.5 Jointing of piping facilities .....	14
2.5.6 Measures for absorption of expansion and contraction of piping facilities .....	19
2.5.7 Insulating measures for piping facilities.....	22
2.5.8 Installation of piping facilities .....	24
2.5.9 Performance of piping facilities.....	30
2.5.10 Marking of piping facilities .....	30
2.6 Governor (Station) Standard<Deleted on July 26, 2013> .....	30

2.7 Accident Prevention Facility Standard.....	31
2.7.1 Installation of overpressure safety devices <Revised on December 2, 2009> .....	31
2.7.2 Installation of gas leak detection and alarm systems <Revised on January 3, 2011> .....	38
2.7.3 Installation of explosion-proof electric facilities.....	40
2.7.4 Installation of ventilation systems <Revised on July 26, 2013> .....	40
2.7.5 Installation of hazard monitoring and control devices.....	42
2.7.6 Installation of corrosion protection systems <Newly established on July 26, 2013> .....	45
2.7.7 Installation of safety grounding system <Newly established on July 26, 2013> .....	45
2.7.8 Installation of lightning arrestors <Newly established on October 14, 2013> .....	45
2.8 Damage Control Facility Standard .....	46
2.8.1 Installation of dikes (not applicable).....	46
2.8.2 Installation of protection walls .....	46
2.8.3 Installation of sprinkler systems (currently not used).....	47
2.8.4 Installation of detoxification facilities (currently not used).....	47
2.8.5 Installation of neutralization and transfer facilities (currently not used).....	47
2.8.6 Installation of emergency shutoff devices .....	47
2.9 Associated Facilities Standard .....	48
2.9.1 Installation of measuring facilities (currently not used).....	48
2.9.2 Installation of emergency power systems <Revised on July 26, 2013> .....	48
2.9.3 Installation of pressure recorders (currently not used).....	48
2.9.4 Installation of communication systems.....	49
2.9.5 Installation of operation facilities <Revised on July 26, 2013> .....	49
2.9.6 Installation of stable supply facilities (currently not used).....	50
2.9.7 Installation of vent stacks.....	50
2.9.8 <Deleted on January 7, 2015>.....	51
2.10 Marking Standard.....	51
2.10.1 Boundary markings and warning signs <Newly established on July 26, 2013> .....	51
2.10.2 Installation of boundary fences<Revised on July 26, 2013>.....	52
3. Technical Standard.....	52
3.1 Safety Maintenance Standard (currently not used) .....	53
3.2 Transferring and Filling Standard (currently not used) .....	53
3.3. Inspection Standard.....	53
3.3.1 Inspection of overall installation (currently not used).....	53
3.3.2 Inspection of foundations (currently not used) .....	53
3.3.3 Inspection of storage facilities (not applicable).....	53
3.3.4 Inspection of gas facilities (currently not used).....	53



3.3.5 Inspection of piping facilities<Newly established on July 26, 2013> .....	53
3.3.6 Overhaul of governors <Revised on October 14, 2013> .....	53
3.3.7 Inspection of accident prevention facilities .....	53
3.3.8 Inspection of damage control facilities (currently not used) .....	54
3.3.9 Inspection of associated facilities <Newly established on July 26, 2013> .....	54
4. Inspection Standard .....	54
4.1 Inspection Items .....	54
4.1.1 Intermediate inspection (not applicable) .....	54
4.1.2 Construction supervision .....	54
4.1.3 Regular inspection <Revised on July 26, 2013> .....	55
4.1.4 Occasional inspection .....	55
4.2 Inspection Methods .....	56
4.2.1 Intermediate inspection (not applicable) .....	56
4.2.2 Construction supervision and regular inspection .....	56
4.2.3 Occasional inspection .....	65
4.2.4 Other inspection methods .....	65



# Code for Facilities, Technology and Inspection for Governor Stations and Valve Stations of Gas Wholesale Business

## 1. General

### 1.1 Scope

This code applies to the installation, operation, inspection and supervision of governors (governor stations) and valve stations among the gas facilities of gas wholesale business operators (inclusive of the installers of gas supply installations other than urban gas business operators in conformity to the Act, Article 39-2, Clause 1) in conformity to the Urban Gas Business Act (hereinafter to be referred to as "the Act"), Article 2, 2 and 5.

### 1.2 Validity of Code

**1.2.1** This Code has passed the deliberation and resolution by the Gas Technical Standards Committee (Bill No. 2019-4, May 17, 2019) in conformity to the High-Pressure Gas Safety Control Act, Article 33-2 in accordance with the Act, Article 17-5, 2, has been approved by the Minister of Industry, Trade & Energy (Notification No. 2019-375 of the Ministry of Industry, Trade & Energy, June 14, 2019) and is valid and effective as detailed standards in conformity to the Act, Article 17-5, Clause 1.

**1.2.2** Conformity to this Code is deemed to conform to Table 5, 2 of the Enforcement Rule of the Act (hereinafter referred to as "Enforcement Rule") in accordance with the Act, Article 17-5, 4. <Revised on August 7, 2015 and August 10, 2018>

### 1.3 Definitions

The meanings of the terms used in this Code are as follows:

**1.3.1** "Gas supply installations" mean the installations for manufacturing or supplying gas and